

# 3M™ Flexible Air Sealing Tape FAST-F 8067E

Holder/Issued to

## 3M Svenska AB

Bollstanäsvägen 3, 191 89 Sollentuna, Sweden

Organisation number: 556021-9684

Phone: +46 (0)8-92 21 00, Fax: 0+46 (0)8-754 55 37

E-mail: [kundservice@mmm.com](mailto:kundservice@mmm.com) , Web: [www.3m.com](http://www.3m.com)

### Product description

3M™ Flexible Air Sealing Tape FAST-F 8067E, flexible single sided jointing tape with age resistant acrylic adhesive, intended for water vapour barriers and as sealing around window and door installations.

### Intended use

Jointing, installation, sealing and repairation of water vapour barriers, intended for water vapour barriers and as air sealing around window and door installations. For verified substrates, see comments below.

### Approval

The product has been found to meet the requirements in the following sections of Boverket Building Regulations (BBR): issued by the National Board of Housing, Building and Planning.

Moisture, General

6:51, first sentence

Moisture safety

6:53, first sentence

Air tightness

6:531

The product has been verified against certification rule CR 031 with the addition of air tightness for installations of windows.

### Associated documents

"Monteringsanvisning 3M FAST-F 8067E", version BR18 4004-1 SE 170622.

### Control

The factory production control (FPC) is monitored by an independent inspection body.

Control agreement: 210-12-0013, Inspection body: RISE Research Institutes of Sweden.

When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated documents.

### Manufacturing place

Production control includes the following place:

3M Wrocław sp.z o.o, Wrocław, Polen.

Certificate no. SC1385-11 | 2017-06-27

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-501 15 Borås, Sweden

Tel: +46 10-516 50 00

[certifiering@ri.se](mailto:certifiering@ri.se) | [www.ri.se](http://www.ri.se)



## Marking

The product is to be marked at the factory. The marking consists of a label on every packing supplied and includes:

Holder of certificate  
Manufacturing place  
P-mark  
Certification body  
Product type designation  
Certificate number  
Length/ Width  
Consecutive manufacture no./date of production  
Inspection body

3M  
3M Wrocław sp.z o.o, Wrocław, Polen  
RISE Certifying  
3M™ Flexible Air Sealing Tape FAST-F 8067E  
SC1385-11  
Value/ Value  
nr/datum  
RISE

## Basis for judgement/approval

Rapports FX015633, PX24302, FX201845, 4F016892B, 6F027760A and 6F003517 from SP Technical Research Institute of Sweden.

## Comments

The tape shall be packed in such a way that it will not be exposed to UV radiation during storage. The durability of the product is deemed to be at least 50 years, provided that it is handled and applied in accordance with the associated documents. The product has been verified against the following substrates: gypsum plasterboard, spruce structural timber, alkyd and acrylic paint.

This approval supersedes the previous approval with the same number dated 4 May, 2016, valid through 14 June 2017.

## Validity

Valid through 2017-06-26.

Håkan Thiman

Stefan Coric