

# Certificate

## SC0794-15

The product described below and production control has been found to comply with Building Regulations of the National Board of Housing Building and Planning (BBR) with reference to and under conditions described in this certificate.

### 3M FAST-D 8069E, Splicing Tape

#### Holder

3M Svenska AB, Bollstanäsvägen 3, 191 89 Sollentuna  
Organisation number: 556021-9684  
Tel: 08-92 21 00, Fax: 08-92 23 45  
E-mail: [kundservice@mmm.com](mailto:kundservice@mmm.com), Internet: [www.3m.se](http://www.3m.se)

#### Product

3M FAST-D 8069E is an age resistant double-sided jointing tape with acrylate adhesive. Supplied in width from 25 mm upwards.

#### Intended use

Splicing, installation, joining, and sealing of constructions foils made of polyethylene, intended as water vapour barriers.

#### Approval

The product has been found to meet the requirements in the following sections of Boverket Building Regulations (BBR): issued by the National Board of Housing, Building and Planning.

Moisture, General	6:51, first sentence
Air tightness	6:531

The product has been assessed against the Certification Rule CR 031, splice materials for flexible barrier.

#### Associated documents

“Monteringsanvisning 3M FAST-D 8069E”, dated 160422.

#### Control

The factory production control (FPC) is monitored by an independent inspection body.  
Control agreement: 210-12-0013, Inspection body: SP.

When the building proprietor performs inspection at the building site, he shall check the markings to ensure that the correct products have been supplied and that they are used in accordance with the requirements stated in the approval and the associated document.

#### Manufacturer

Production control includes the following sites:  
3M, Värnamo and/or 3M Wrocław



### Marking

The product is to be marked at the factory. The marking consists of a label on every product supplied and includes:

Approval holder  
Manufacturing site  
P-mark  
Certification body  
Product type designation  
Certificate number  
Length, Width  
Consecutive manufacture No.  
Inspection body

**3M Svenska AB**  
**Wroclaw, Polen**  
**Þ**  
**SP Certifiering**  
**3M FAST-D 8069E**  
**SC0794-15**  
**value, value**  
**No.**  
**SP**

### Basis for approval

Report 4F004571, 5F024403-1, and 6F003517 from SP Technical Research Institute of Sweden.

### Comments

The tape shall be packed in such a way that it will not be exposed to UV radiation during storage. The durability of the product is deemed to be at least 50 years, provided that it is handled and applied in accordance with the associated documents.

The product has been verified against the following substrates: gypsum plasterboard, spruce structural timber, alkyd and acrylic paint.

### Period of validity

This certificate is valid until 20 June 2021.

### SP Technical Research Institute of Sweden Certification

Håkan Thiman

Linda Ring Thorén